



Bid Number/बोली क्रमांक (बिड संख्या):  
GEM/2024/B/4785333  
Dated/दिनांक : 21-03-2024

### Bid Document/ बिड दस्तावेज़

Bid Details/बिड विवरण	
Bid End Date/Time/बिड बंद होने की तारीख/समय	20-04-2024 10:00:00
Bid Opening Date/Time/बिड खुलने की तारीख/समय	20-04-2024 10:30:00
Bid Offer Validity (From End Date)/बिड पेशकश वैधता (बंद होने की तारीख से)	90 (Days)
Ministry/State Name/मंत्रालय/राज्य का नाम	Ministry Of Finance
Department Name/विभाग का नाम	Department Of Economic Affairs
Organisation Name/संगठन का नाम	Security Printing And Minting Corporation Of India Limited (spmci)
Office Name/कार्यालय का नाम	Janpath
Total Quantity/कुल मात्रा	110
Item Category/मद केटेगरी	LED Luminaire (for Road and Street Lights) as per IS 10322, IS 16107, IS 16108, IS 16103, IS 10322 (Q3) , LED Luminaire for High Bay Lighting (Q3) , Led Flood Light (Q3)
MSE Exemption for Years of Experience and Turnover/ अनुभव के वर्षों से एमएसई छूट	No
Startup Exemption for Years of Experience and Turnover/ अनुभव के वर्षों से स्टार्टअप छूट	No
Bid to RA enabled/बिड से रिवर्स नीलामी सक्रिय किया	No
Type of Bid/बिड का प्रकार	Two Packet Bid
Primary product category	LED Luminaire (for Road and Street Lights) as per IS 10322, IS 16107, IS 16108, IS 16103, IS 10322
Time allowed for Technical Clarifications during technical evaluation/तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय	4 Days
Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
Evaluation Method/मूल्यांकन पद्धति	Total value wise evaluation

### EMD Detail/ईएमडी विवरण

--

Required/आवश्यकता	No
-------------------	----

**ePBG Detail/ईपीबीजी विवरण**

Required/आवश्यकता	No
-------------------	----

**Splitting/विभाजन**

Bid splitting not applied/बोली विभाजन लागू नहीं किया गया.

**MII Purchase Preference/एमआईआई खरीद वरीयता**

MII Purchase Preference/एमआईआई खरीद वरीयता	Yes
--	-----

**MSE Purchase Preference/एमएसई खरीद वरीयता**

MSE Purchase Preference/एमएसई खरीद वरीयता	Yes
---	-----

1. Preference to Make In India products (For bids < 200 Crore):Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate.The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.

2. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% (Selected by Buyer)of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for 25%(selected by Buyer) percentage of total QUANTITY.The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.

3. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc.

This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

**LED Luminaire (for Road And Street Lights) As Per IS 10322, IS 16107, IS 16108, IS 16103, IS 10322 ( 60 pieces )**

**(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)**

Bis Required	Yes
--------------	-----

**Technical Specifications/तकनीकी विशिष्टियाँ**

\* As per GeM Category Specification/जेम केटेगरी विशिष्टि के अनुसार

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	<b>LED Rating (in Watts)/System Wattage/Rated Power</b>	70W
	<b>Luminaire System Efficacy (Lumen/watt)</b>	>/= 100 Lm/Watt
	<b>Ingress Protection (IP Rating) as per IS:10322 (Part 1):1982 latest</b>	IP66
	<b>Warranty for free replacement (in years)</b>	2
ELECTRICAL EFFICIENCY	<b>Input operating Voltage range and frequency</b>	90 to 300 Volts AC at 50 Hz+/-2
THERMAL MANAGEMENT	<b>Operating temperature range</b>	-10°C to 80°C
PROTECTION	<b>The luminaire shall be protected against surges and transients ( Internal)</b>	>/= 8Kv
CONSTRUCTIONAL	<b>Number of electronic control gear (power supplies)</b>	1 No.
	<b>Length of ISI marked three core wire (shall be provided along with supply of material)</b>	50 cm
Reports And Certifications	<b>LED Make</b>	OSRAM / NICHIA / CREE / SAMSUNG / SEOUL / LUMILEDS / PHILIPS / SYSKA / LUMENMAX / EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / REFOND

**Additional Specification Parameters - LED Luminaire (for Road And Street Lights) As Per IS 10322, IS 16107, IS 16108, IS 16103, IS 10322 ( 60 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
TECHNICAL SPECIFICATION	PLEASE REFER ATC OF BID

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Sunilkumar Kewalchand Ramteke	422101,Currency Note Press, Nashik Road Nashik , Maharashtra	60	30

**LED Luminaire For High Bay Lighting ( 30 pieces )**

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

**Technical Specifications/तकनीकी विशिष्टियाँ**

\* As per GeM Category Specification/जेम केटेगरी विशिष्टि के अनुसार

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Installation and commissioning	Yes
	Scope of installation and commissioning	Installation and commissioning includes mounting of lights on roof hooks/fixture and making electrical connections to make the light functional. Wiring is not in scope.
RATINGS	Operating input voltage range (in Volts)	100 to 280
	Luminaire System Wattge (in Watts)	150
	Luminaire System Efficacy - Lumen output - (Lumen/watt)	? 120
	Color Temperature (CCT) +/- 500 K (in Kelvin)	6000 K
	Colour Rendering Index (CRI) (in % age)	? 70
	Power Factor (PF)	? 0.95 at full load

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Ingress Protection (IP) Rating of Luminaire (agreed to furnish test certificates to buyer / consignee on demand)	IP 66
	Impact resistance (If claimed "Yes" - agreed to furnish test certificates to buyer / consignee on demand)	Yes. IK08 (as per IEC 62262:2002)
	Minimum operating temperature range (in deg. C)	-10 to 0
	Maximum operating temperature range (in deg. C)	50.0 - 60.0 Or higher
SAFETY	The luminaire shall be protected against surges and transients ( Internal)	? 5 KV
	The luminaire shall be protected against surges and transients (External)	? 10 KV
	Flame/Fire proof compliance (If claimed - agreed to furnish test certificates to buyer / consignee on demand)	No
	Other compliacne (If claimed - agreed to furnish test certificates to buyer / consignee on demand)	No
CONSTRUCTION	Shape of Luminaire	Round
	Type of mounting	Metallic adjustable Brackets with Eye Bolt
	Installation height range from floor level (in m) - Must declare	15
	Optic Lens	Yes. Polycarbonate-UV stabilised
	Type of Control Gear	Constant Current
	Number of electronic control gear on each luminaire (power supplies) - (in Nos.)	1
	Luminaire fitted with connecting cables for input power	ISI Marked 3 Core cable for input power ( Length:250 mm )
	Accessories for each luminaire	Metallic adjustable Brackets (Stainless steel), SS Eye Bolts (as per IS:4190:1984 latest), Set of Bolt,Nut, Washers (SS), Die cast aluminium brackets

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
MARKING	Marking/Identification details on inside of each luminaire and outside of each packing box	Manufacturer's Name, Model Number, Serial Number, Month and year of manufacturing, Voltage, System Wattage
	Marking/Identification details on each control gear	Manufacturer's Name, Model Number
CERTIFICATIONS	Warranty period (in Months)	24, 36, 48, 60 Or higher
	Availability of test reports from Central Govt. Lab/NABL/ILAC accredited laboratory to prove conformity of the specification	Yes
	Agreed to furnish LM 79 , LM 80 reports from Central Government lab/NABL/ILAC accredited lab	Yes as per IS:16106:2012 latest and as per IS:16105:2012 latest
	Agreed to furnish TM 21 report from Central Government lab/NABL/ILAC accredited lab	Yes

**Additional Specification Parameters - LED Luminaire For High Bay Lighting ( 30 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
TECHNICAL SPECIFICATION	PLEASE REFER ATC OF BID

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Sunilkumar Kewalchand Ramteke	422101,Currency Note Press, Nashik Road Nashik , Maharashtra	30	30

**Led Flood Light ( 20 pieces )**

**(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)**

**Technical Specifications/तकनीकी विशिष्टियाँ**

\* As per GeM Category Specification/जेम केटेगरी विशिष्टि के अनुसार

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
Constructional	<b>LED Rating (in Watts)/System Wattage/Rated Power</b>	120, 150, 160, 180, 200, 240 Or higher <b>(Watt)</b>
	Mounting Plate size	(430mm x 340mm)+/-10mm
	<b>Length of ISI marked three core wire (shall be provided along with supply of material)</b>	50, 100 Or higher <b>(centimeter)</b>
Electrical Efficiency	Input operating Voltage range and frequency	90 to 300 Volts AC at 50 Hz+/-2
	Total Harmonics Distortion (as per IS: 16102)	</=10
Thermal Management	<b>Operating Temperature Range</b>	-10 deg C to +55 deg C
Standards	<b>Warranty for free replacement (in years)</b>	5
	Ingress Protection (IP Rating) as per IS:10322 (Part 1):1982 latest	IP66
Reports And Certifications	LED Make	OSRAM / NICHIA / CREE / SAMSUNG / SEOUL / LUMILEDS / PHILIPS / SYSKA / LUMENMAX / EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / REFOND / NICHIA / CREE / SAMSUNG / SEOUL / LUMILEDS / PHILIPS / SYSKA / LUMENMAX / EVERLIGHT / EDISON / BRIDGE

**Additional Specification Parameters - Led Flood Light ( 20 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
TECHNICAL SPECIFICATION	PLEASE REFER ATC OF BID

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Sunilkumar Kewalchand Ramteke	422101,Currency Note Press, Nashik Road Nashik , Maharashtra	20	30

## Buyer Added Bid Specific Terms and Conditions/क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें

### 1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity by up to 25% of the contracted quantity during the currency of the contract at the contracted rates. Bidders are bound to accept the orders accordingly.

### 2. Buyer Added Bid Specific ATC

Buyer Added text based ATC clauses

#### A) TECHNICAL SPECIFICATION :

#### ITEM NO.01 : LED STREET LIGHT:

LED Street light fixture complete with clamping arrangement for mounting pipe.

- LED Rating (in Watts) 70W
- Luminaire System Efficacy (Lumen/watt)  $\geq$  100 Lm/Watt
- Rated voltage 240 V AC 50 Hz,
- AC Power Factor at full load  $\geq$  0.95
- Driver Efficiency (in %age) Upto 100W:  $\geq$ 85
- Total Harmonics Distortion  $\leq$  10%
- LED chip Efficacy  $\geq$ 130 Lm/Watt
- Colour temperature 6500K
- Working life for LED Minimum 50,000 hours
- Colour Rendering Index(CRI)  $\geq$ 70
- LED Beam Angle  $\geq$ 120
- Optic lens material (UV stabilized) Poly carbonate lens
- Input operating Voltage range and frequency 90 to 300 Volts AC at 50 Hz ( +/- 2 %)
- Automatic Higher voltage cut off
- Heat sink should be die-cast aluminium along with sufficient heat sink fins to dissipate heat effectively.



- Operating temperature range -10°C to 80°C
- Short circuit Protection ,Over load protection ,Over Voltage protection & Reverse polarity protection
- The luminaire shall be protected against surges and transients ( Internal)  $\geq 8\text{Kv}$
- The luminaire shall be protected against surges and transients of  $\geq 10\text{KV}$  (External)
- The Luminaires casing/housing (single piece housing) shall be pressure die casted aluminium alloy with higher thermal conductivity & The luminaire body must be corrosion resistant powder coated
- All fasteners must be of stainless steel
- Protection of the entire housing (both LED section and driver section) as per latest IS IP66
- Extruded silicon loop gasket shall be provided in the lantern body to ensure a weather proof seal between the UV Glass cover and the metal housing to exclude the entry of the dust, water, insects etc.,
- Luminaires light transparency should be of Toughened glass
- Light Source SMD LED Chip as per latest standards.
- Driver components shall be industrial grade or above
- Suitable connector shall be provided for LED connection between driver output and LED
- Length of ISI marked three core wire be provided along with supply of material minimum 0.5Mtr
- "Manufactures Name and and brand on the aluminium die cast body Engraved/Embossed
- Ingress Protection (IP Rating) IP66
- LED Luminaire conformity to latest IS standards.
- Energy rating : 5 star (from Govt approved agency)
- Warranty : Minimum 1 year
- Make : Wipro/ Havel's/ Crompton/ Philips/ Any standard
- Qty : 60Nos

**ITEM 2 :- LED HIGH BAY LIGHT 150 WATT .**

- Rated voltage (in Volts) 240 V, AC
- Frequency (in Hz) 50 +/-2Hz
- Operating input voltage range (in Volts) 100 to 280 ( +/-2 %)
- Luminaire System Wattage (in Watts) : 150Watt
- LED chip Efficacy (Lumen/watt)  $\geq 130$
- Luminaire System Efficacy - Lumen output (Lumen/watt)  $\geq 120$
- Color Temperature (CCT) +/- 500 K (in Kelvin) 6000 K

- Color Rendering Index (CRI) (in % age)  $\geq 70$
- Power Factor (PF)  $\geq 0.95$  at full load
- Total Harmonics Distortion (in %age)  $\leq 10$
- Beam angle of light source (in degree)  $\geq 120$
- LED Life  $\geq 50000$  Hours
- Ingress Protection (IP) Rating of Luminaire ( Shall furnish test certificates to buyer / consignee on demand) IP66
- Cover: Toughened transparent Glass 4 mm. thick or better
- Surge voltage withstand capacity: 4KV or better
- Short circuit Protection ,Over load Protection ,Over Voltage protection &Reverse polarity protection
- Shape of Luminaire Round with powder coated
- "Manufactures Name and brand on the aluminium die cast body "Engraved/Embossed
- Color of Luminaire White/Black
- Suitable connector between driver output and LED
- Warranty : Minimum 1 years
- Safety requirements for Electronic Control Gear for LED Modules :as per IS:15885
- DC or AC supplied electronic control gear for LED modules - Performance requirements as per latest standards.
- Method of Measurement of Lumen Maintenance of solid state light (LED) sources as per latest standards.
- Method of Electrical and Photometric Measurements solid state light (LED) sources as per latest standards.
- Enclosure protection (Ingress Protection) as per Latest standards.
- Energy rating : 5 star (from Govt approved agency)
- Make : Wipro/ Havel's/ Crompton/ Philips/ Any standard
- Warranty : 1 year minimum.
- Qty : 30Nos

**ITEM 3 : LED FLOOD LIGHT 120 WATT.**

- AC Power Factor at full load  $\geq 0.95$
- Rated voltage 230 V/240V AC 50 Hz
- LED Rating : 120 Watt

- Input operating Voltage range and frequency 90 to 300 Volts AC at 50 Hz+/-2
- Total Harmonics Distortion (as per IS: 16102)  $\leq 10$
- Automatic Higher Cut off voltage above 300 volt
- Light Source SMD LED Chip as per LM 80/IS16
- Driver Efficiency (in %age) Up to 100W:  $\geq 85\%$
- Working life for LED (as per LM-80 and LM 21 reports)  $\geq 50000$
- LED Beam Angle (degree)  $\geq 120$
- Colour temperature 6000 +/- 500K
- LED chip Efficacy  $\geq 135$  Lm/Watt
- Colour Rendering Index(CRI)  $\geq 70$
- Heat sink should be die-cast aluminium along with sufficient heat sink fins to dissipate heat effectively
- Over Voltage Protection ,Short Circuit Protection , Over Load Protection & reverse polarity protection .
- The luminaire shall be protected against surges and transients ( Internal) $\geq 5KV$
- The luminaire shall be protected against surges and transients of  $\geq 10KV$  (External)
- Operating Temperature Range -10 deg C to +55 deg C
- The luminaire body must be corrosion resistant powder coated
- Protection of the entire housing as per IS:10322 (Part 1):1982 latest IP66
- Suitable connector shall be provided for LED connection between driver output and LED
- "Manufactures Name and brand on the aluminium die cast body "Engraved/Embossed
- Length of ISI marked three core wire provided along with supply minimum 0.5mtr
- Toughed Glass shall not get discoloured shall not suffer degradation due to heat and ageing within warranty period.
- Warranty : Minimum 1 years
- The Luminaires casing/housing shall be Spun Aluminium/Die Cast Aluminium with higher thermal conductivity
- LED Floodlight Fixture complete with driver supply connection leads and adjustable mounting bracket.
- Energy rating : 5 star (from Govt approved agency)
- Warranty : 1 year minimum.
- Make : Wipro/ Havel's/ Crompton/ Philips/ Any standard
- Qty : 20 Nos .

## **B) MINIMUM ELIGIBILITY CRITERIA**

1. The bidder should give undertaking/declaration that they have read and understood all the terms (with technical specification) & conditions of tender documents and submitting unconditional acceptance to all terms & conditions.

2. The bidder shall submit offered product catalogue with technical bid.

### **3. Certificates**

Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.

### **4. Warranty**

Warranty period of the supplied products shall be 1 years from the date of final acceptance of goods or after completion of installation, commissioning & testing of goods (if included in the scope of supply), at consignee location. OEM Warranty certificates must be submitted by Successful Bidder at the time of delivery of Goods. The seller should guarantee the rectification of goods in case of any break down during the guarantee period. Seller should have well established Installation, Commissioning, Training, Troubleshooting and Maintenance Service group in INDIA for attending the after sales service. Details of Service Centres near consignee destinations are to be uploaded along with the bid.

### **5. Generic**

While generating invoice in GeM portal, the seller must upload scanned copy of GST invoice and the screenshot of GST portal confirming payment of GST.

## **Disclaimer/अस्वीकरण**

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. Any clause(s) incorporated by the Buyer regarding following shall be treated as null and void and would not be considered as part of bid:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process.
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.

13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

[This Bid is also governed by the General Terms and Conditions/ यह बिड सामान्य शर्तों के अंतर्गत भी शासित है](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws./जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो।बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।

**---Thank You/धन्यवाद---**