



Bid Number/बोली क्रमांक (बिड संख्या):  
GEM/2024/B/5428438  
Dated/दिनांक : 07-10-2024

### Bid Document/ बिड दस्तावेज़

Bid Details/बिड विवरण	
Bid End Date/Time/बिड बंद होने की तारीख/समय	06-11-2024 10:00:00
Bid Opening Date/Time/बिड खुलने की तारीख/समय	06-11-2024 10:30:00
Bid Offer Validity (From End Date)/बिड पेशकश वैधता (बंद होने की तारीख से)	120 (Days)
Ministry/State Name/मंत्रालय/राज्य का नाम	Ministry Of Finance
Department Name/विभाग का नाम	Department Of Economic Affairs
Organisation Name/संगठन का नाम	Security Printing And Minting Corporation Of India Limited (spmci)
Office Name/कार्यालय का नाम	Janpath
Total Quantity/कुल मात्रा	2
Item Category/मद केटेगरी	SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF HIGH MAST WITH LED FLOOD LIGHTS , SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF LED STREET LIGHT
GeMARPTS में खोजी गई स्ट्रिंग / Searched Strings used in GeMARPTS	SITC of LED street light With Power Cables & Earthing System
GeMARPTS में खोजा गया परिणाम / Searched Result generated in GeMARPTS	Category not available on GeM for the text string uploaded by the buyer
अधिसूचना के लिए चयनित प्रासंगिक श्रेणियाँ / Relevant Categories selected for notification	• LED Luminaire (for Road and Street Lights) as per IS 10322, IS 16107, IS 16108, IS 16103, IS 10322
Minimum Average Annual Turnover of the bidder (For 3 Years)/बिडर का न्यूनतम औसत वार्षिक टर्नओवर (3 वर्षों का)	13 Lakh (s)
Years of Past Experience Required for same/similar service/उन्हीं/समान सेवाओं के लिए अपेक्षित विगत अनुभव के वर्ष	1 Year (s)
MSE Exemption for Years Of Experience/अनुभव के वर्षों से एमएसई छूट/ and Turnover/टर्नओवर के लिए एमएसई को छूट प्राप्त है	Yes

<b>Bid Details/बिड विवरण</b>	
<b>Startup Exemption for Years Of Experience/अनुभव के वर्षों से स्टार्टअप छूट/ and Turnover/ टर्नओवर के लिए स्टार्टअप को छूट प्राप्त है</b>	Yes
<b>Document required from seller/विक्रेता से मांगे गए दस्तावेज़</b>	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
<b>Do you want to show documents uploaded by bidders to all bidders participated in bid?/</b>	No
<b>Past Performance/विगत प्रदर्शन</b>	40 %
<b>Bid to RA enabled/बिड से रिवर्स नीलामी सक्रिय किया</b>	Yes
<b>RA Qualification Rule</b>	50% Lowest Priced Technically Qualified Bidders
<b>Type of Bid/बिड का प्रकार</b>	Two Packet Bid
<b>Primary product category</b>	SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF HIGH MAST WITH LED FLOOD LIGHTS
<b>Time allowed for Technical Clarifications during technical evaluation/तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय</b>	4 Days
<b>Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)</b>	No
<b>Evaluation Method/मूल्यांकन पद्धति</b>	Item wise evaluation/
<b>Arbitration Clause</b>	No
<b>Mediation Clause</b>	No

#### **EMD Detail/ईएमडी विवरण**

Advisory Bank/एडवाइजरी बैंक	Indusind bank
Schedule 1 EMD Amount/ईएमडी राशि (In INR)	62100
Schedule 2 EMD Amount/ईएमडी राशि (In INR)	38600

#### **ePBG Detail/ईपीबीजी विवरण**

Advisory Bank/एडवाइजरी बैंक	Indusind bank
ePBG Percentage(%) /ईपीबीजी प्रतिशत (%)	5.00

Duration of ePBG required (Months)/ईपीबीजी की अपेक्षित अवधि (महीने).

17

(a). EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy./जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित केटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज़ प्रस्तुत करने हैं। एमएसई केटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।

(b). The EMD Amount will be applicable for each schedule/group selected during Bid creation.

(c). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable./ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए।

**Beneficiary/लाभार्थी :**

General Manager (TO) & HOD  
CURRENCY NOTE PRESS, JAIL ROAD, NASHIK ROAD, NASHIK-422101  
(Currency Note Press, A Unit Of Spmcil)

**MII Purchase Preference/एमआईआई खरीद वरीयता**

MII Purchase Preference/एमआईआई खरीद वरीयता

Yes

**MSE Purchase Preference/एमएसई खरीद वरीयता**

MSE Purchase Preference/एमएसई खरीद वरीयता

Yes

1. If the bidder is a Micro or Small Enterprise as per latest definitions under MSME rules, the bidder shall be exempted from the requirement of "Bidder Turnover" criteria and "Experience Criteria" subject to meeting of quality and technical specifications. If the bidder is OEM of the offered products, it would be exempted from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. In case any bidder is seeking exemption from Turnover / Experience Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer.
2. If the bidder is a Startup, the bidder shall be exempted from the requirement of "Bidder Turnover" criteria and "Experience Criteria" subject to their meeting of quality and technical specifications. If the bidder is OEM of the offered products, it would be exempted from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. In case any bidder is seeking exemption from Turnover / Experience Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer.
3. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
4. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

5. Preference to Make In India products (For bids < 200 Crore): Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate .The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023.

[OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.

6. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

7. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

8. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 40% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

9. Reverse Auction would be conducted amongst first 50% of the technically qualified bidders arranged in the order of prices from lowest to highest. Number of sellers eligible for participating in RA would be rounded off to next higher integer value if number of technically qualified bidders is odd (e.g. if 7 bids are technically qualified, then RA will be conducted amongst L-1 to L-4). In case number of technically qualified bidders are 2 or 3, RA will be between all without any elimination. If Buyer has chosen to split the bid amongst N sellers, then minimum N sellers would be taken to RA round. In case Primary products of only one OEM are left in contention for participation in RA based on lowest 50% bidders qualifying for RA, the number of sellers qualifying for RA would be increased to get at least products of one more OEM (directly participated or through its reseller) if available. Further, if bid(s) of any seller(s) eligible for MSE preference is / are coming within price band of 15% of Non MSE L-1 or if bid of any seller(s) eligible for Make in India preference is / are coming within price band of 20% of non MII L-1, then such MSE / Make in India seller shall also be allowed to participate in the RA process.

**Evaluation Method** ( Item Wise Evaluation Method )

Contract will be awarded schedulewise and the determination of L1 will be done separately for each schedule. The details of item-consignee combination covered under each schedule are as under:

Evaluation Schedules	Item/Category	Quantity
Schedule 1	Supply, Installation, Testing & Commissioning Of High Mast With Led Flood Lights	1
Schedule 2	Supply, Installation, Testing And Commissioning Of Led Street Light	1

### SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF HIGH MAST WITH LED FLOOD LIGHTS ( 1 set )

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

#### Technical Specifications/तकनीकी विशिष्टियाँ

Buyer Specification Document/क्रेता विशिष्टि दस्तावेज़	<a href="#">Download</a>
--	--------------------------

#### Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्र

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्र	Delivery Days/डिलीवरी के दिन
1	Ashish Suresh Shende	422101,Currency Note Press, Nashik Road Nashik , Maharashtra	1	90

### SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF LED STREET LIGHT ( 1 set )

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

#### Technical Specifications/तकनीकी विशिष्टियाँ

Buyer Specification Document/क्रेता विशिष्टि दस्तावेज़	<a href="#">Download</a>
--	--------------------------

#### Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्र

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Ashish Suresh Shende	422101,Currency Note Press, Nashik Road Nashik , Maharashtra	1	90

## Buyer Added Bid Specific Terms and Conditions/क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें

### 1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity by up to 25% of the contracted quantity during the currency of the contract at the contracted rates. Bidders are bound to accept the orders accordingly.

### 2. Buyer Added Bid Specific ATC

Buyer Added text based ATC clauses

#### **A) TECHNICAL SPECIFICATION:**

-

#### **SCHEDULE : 1**

### **Job work of Supply, Installation, Testing & Commissioning of High Mast with LED Flood Lights With Power Cables & Earthing System On Turnkey Basis at CNP-IV:**

#### 1. Supply of Motorized High Mast with 250W LED Light system:

Comprising minimum 06 Nos. of LED flood light on each Motorized High mast pole of 12.5 mtr height.

Details of High mast:

#### A) LED Flood light:

Supply of 250 W LED Flood Light with Epoxy powder coated die-cast Aluminium housing with heat sink for efficient thermal management, sturdiness & excellent corrosion resistant suitable for outdoor application .

System wattage consist of 250 W with composite Lens cover for viewing angle of 30 - 90° to ensure better uniformity Operating voltage range: 140-270V AC ,System Lumen Output min 25000 to 30,000 Lumen in max 250 w ,IP66 with 5700 - 6500 K CCT with PF > 0.95,CRI > = 70 and,THD % < 10, with Min 10KV Surge protection in Built.With Make of LED Flood Light - Bajaj / Halonex / Philips / Havells/Equivalent

#### TEST REPORT TO BE SUBMITTED ON DEMAND

Test Report LM 79 FOR Complete LED Luminaries and LM 80 for LED Chip as well as PHOTO BIOLOGICAL SAFETY for LED chip from NABL accredited lab.

B) High Mast pole: Hot dip Galvanized High Mast will be 12.5 m high ( octagonal /polygonal pole with having bottom (base) of 350 mm A/F, top 150 mm A/F PCD 275 or better. With base plate 20mm thick or better based on proven design conforming to international standards, to give an assured performance High mast should be with proper Aviation Lamp.

i) Construction: For the environmental protection of the mast, the entire fabricated mast will be hot dip galvanized, internally & externally, having a uniform thickness of 65 microns.

ii) Door Opening: An adequate door opening will be provided at the base of the mast & the opening will be such that it permits clear access to equipment like winches, cables, plug & socket, etc. & also facilitate easy removal of the winch. The door opening will be complete with a close fitting, vandal resistant, weather proof door, provided with a heavy-duty double internal lock with special paddle key.

iii). Dynamic Loading: The mast structure will be suitable to sustain an assumed maximum reaction arising from a wind speed as per the standards. The design life of the mast shall be minimum of 35 years.

iv) Lantern Carriage:

a. Fabrication: A fabricated Lantern Carriage shall be provided for fixing & holding the flood light fitting & control gear boxes. The Lantern Carriage shall be of special design & shall be of steel tube construction, the tubes acting as conduits for wires, with holes fully protected by grommets. The Lantern Carriage shall be so designed & fabricated to hold the required number of flood light fittings & the control gear boxes, & also to have a perfect self-balance. The inner lining of the carriage shall be provided with protective PVC arrangement, so that no damage is caused to the surface of the mast during the raising & lowering operation of the carriage.

v) Junction Box: Weather proof junction box with IP65 enclosure, made of Cast Aluminium shall be provided on the Carriage Assembly as required, from which the inter-connections to the designed number of the flood light luminaries & associated control gear fixed on the carriage shall be made.

vi) Motorized Raising & Lowering Mechanism: For the installation & maintenance of the luminaries & lamps, it will be necessary to lower & raise the Lantern Carriage Assembly. To enable this, a suitable Winch Arrangement shall be provided, with winch fixed at the base of the mast & the specially designed head frame assembly the top.

vii) Winch: The winch will be of completely self-sustaining type, without the need for brake shoes, springs or clutches. Each driving spindle of the winch will be positively locked when not in use, gravity activated PAWLS. Individual drum also will be operated for fine adjustment of lantern carriage. The capacity, operating speed, safe working load of the recommended lubrication & serial number of the winch will be clearly marked on each winch. The gear ratio may be according to manufacturer's standard. However, the minimum working load will be not less than 400Kg. The Winch will be self-lubricating type by means of an oil bath & the oil will be readily available grades of reputed producers. The winch drums will be grooved to ensure perfect seat for stable & tidy rope lay, with no chances of rope slippage. The rope termination in the winch will be such that distortion or twisting is eliminated & at least 5 to 6 runs of rope remains on the drum even when lantern carriage is fully lowered & rested on the rest pads. It will be possible to operate the winch manually by a suitable handle & / or by an external power tool. It will be possible to remove the double drum after dismantling, through the door opening provided at the base of mast. Also, a winch gear box for simultaneous & reversible operation of the double drum winch will be provided as part of the contract.

viii) Head Frame: The head frame which is to be designed as a capping unit of the mast will be of welded steel construction galvanized both internally & externally after assembly. The top pulley will be appropriate diameter, large enough to accommodate the stain-less steel wire ropes & the multi-core electric cable. The pulley block will be made of non-corrosive material, & will be of die cast aluminum alloy (LM-6). Pulley made of synthetic material such as plastic or PVC is not acceptable.

Self-lubricating bearings & stain-less steel shaft will be provided to facilitate smooth & maintenance free operation for a long period. The pulley assembly will be fully protected by a canopy galvanized externally & internally. Close fittings guides & sleeves will be provided to ensure that the ropes & cables do not dislodge from their respective positions in the grooves. The head frame will be provided with guides & stops with PVC buffer for docking the lantern carriage.

ix) Stain-less Steel Wire Ropes: The suspension system will be essentially be without intermediate joint & will consist of any non-corrosive stain-less steel. The stain-less steel wire ropes will be of 7/19 construction, the central core being of the same material. The overall diameter of the rope approx. 6 mm. The breaking load of each rope will not be less than approx. 2350kg individually, giving factor of safety. The end construction of rope to winch drum will be fitted with telluride. The thimbles will be secured on ropes by compression splices. Two continuous lengths of stain-less steel wire ropes will be used in the system & no intermediate joints are acceptable in view of the required safety. No intermediate joints either bolted or else are provided on the wire ropes between winch & lantern carriage.

- A suitable terminal box will be provided as part of the contract at the base compartment of the high mast for terminating the incoming cable. The electrical connections from the bottom to the top will be made by 3 cores 2.5 sq.mm. Copper cable.

- At the top there will be weather proof junction box to terminate the trailing cable. Connections from the top junction box to the individual luminaries will be made by using 3 cores 1.5 sq.mm. Copper flexible PVC cables of reputed make.

- High Mast will be provided with Separate 63 Amp MCB at the bottom Junction box for Local control of High mast.

- The system will have in-built facilities for testing the luminaries while in lowered position.

Make of High mast – Bajaj, Havells, Crompton, Wipro, Halonex or Equivalent

Qty: 06 no.s

#### II Installation, commissioning & testing of High Mast:

1. The firm shall carry out the installation, commissioning of the High Mast pole with necessary foundation as per design confirming to IS with minimum 06nos. of Tor steel foundation bolt of not less than 25mm dia.

2. The firm shall carry out the installation, testing & commissioning of LED High Mast flood light on lantern carriage of the Pole.

3. All Job work shall be carried out on Turnkey basis i.e. pole foundation, pole installation, fitting of high mast, MCB box & entire wiring of high mast etc.

- 4 The firm shall supply any other material, accessories, hardware & electrical switchgears, if required for installation work of entire High mast system.

5. The firm shall ensure that each pole is provided with proper earthing.

6. The firm shall carry out required digging & construction of Foundation as per the applicable standards.

7. The firm shall carry out Installation of High mast & all the hardware required for the Installation.

Qty: 06 each

#### III. Supply of 35 sq. mm. x 3.5 core XLPE insulated Aluminium multi strand conductor Armoured Po



wer cable for feeding electrical power from main feeder pillar to 06 nos of High Mast at CNP IV.

Technical Specification :

35 Sq mm x 3.5core Aluminium Power Cable :

XLPE Insulated, inner sheathed, Armoured Power Cable

Conductor : Aluminium multi-strand

Voltage Grade : 1.1 KV ,Size : 35 Sq.mm , Core : 3.5

Confirming to : IS standards as applicable

Nominal System Voltage : 440 V +/- 10%

Nominal System Frequency : 50 Hz +/-3%

Conductor type : Stranded

Insulating Material : XLPE

Core Identification Strips : Red , Yellow, Blue & Black

Make : POLYCAB/KEI/equivalent Qty:650 mtrs (approx)

IV.Laying & Installation of Underground 35 sq mm x 3.5core XLPE insulated Aluminium conductor Armoured Power cable from the Main feeder Pillar of CNP 4 to 06 No's of High masts.

1. The firm shall carry-out the Underground laying & installation work of above supplied power cable from the Main feeder Pillar of CNP 4 to 06 Nos of High masts.
  2. The firm shall carry-out the laying & installation work of above supplied power cable from Main feeder Pillar to High-mast trough underground Trench.
  3. Cable trench (below ground) will be approximately 1.5 Feet deep.
  4. Cable shall be laid underground through DWC HDPE Pipe ISI Mark along with all accessories like socket, bend, coupler etc. as per IS 14930 with all fittings including excavation & refilling the trench but excluding sand cushioning dia suitable for 35 Sq mm Cable.
  5. If required, the firm shall provide the cable marker throughout the route of cable to trace the cable.
  6. The Aluminium lugs shall be used for connection to Aluminium bus-bar.
  7. The accessories like Lugs, cable glands etc. will be of reputed make like Dowells, Jainson, Etc
- Qty:650 mtrs (approx)

V. Cable Trench Digging, filling & leveling Work:

1. Carry out digging work of Cable Trench for the prescribed cable route as required.
2. Cable trench (below ground) will be approximately 1.5 Feet deep.
3. Cable shall be laid underground through DWC HDPE Pipe ISI Mark along with all accessories like socket, bend, coupler etc. as per IS 14930 with all fittings including excavation & refilling the trench but excluding sand cushioning dia .suitable for 35 Sq. mm Cable.

Qty:490 mtrs

## VI. Supply of DWC HDPE Pipe Suitable for 35 Sq.mm Cable

1. Supply of DWC HDPE Pipe ISI Mark along with all accessories like socket, bend, coupler etc. as per IS 14930

2. Pipe Dia Suitable for 35 Sq.mm Cable

Qty: 490 mtrs (approx)

VII : Supply, Laying & Installation of 6 SWG GI Earthing wire along with above Armored Power cable from Main feeder Pillar at CNP IV Gate to 06 Nos of High Masts.

1. Firm shall Supply & carry-out the laying & installation work of above supplied 6 SWG GI Earthing wire in along with power cable from Main feeder Pillar at CNP IV Gate to 06 Nos of High Masts.

2. firm shall fix and route along with the cable through the route specified by CNP's Authority from Surface or underground

3. The Aluminium / copper lugs will be used for connection to Aluminum cable/ copper bus-bar and cable

Qty: 550 mtrs

High tensile low carbon steel rod of 2 Mtrs length & 32 mm dia with 100 micron (average) molecularly bonded copper on the outer surface.

- Make - Indelec/ equivalent

- Qty :- 06 Nos.

## VIII) MAINTENANCE FREE EARTHING SYSTEM with 25x5mm GI Strip

Provision of Maintenance free Low resistance High conductivity Type Earthing system With Back-fill compound.

A) Earth Electrode :-

- High tensile low carbon steel rod of 2 Mtrs length & 32 mm dia with 100 micron (average) molecularly bonded copper on the outer surface.

- Make - Indelec/ equivalent

- Qty :- 06 Nos.

B) Carbon Based Grounding Compound:-

- Back-fill compound strictly be an Activated Carbon based conductive type, will not depend on the continuous presence of water / moisture / salt to maintain its conductivity.

- Back-fill compound will be electronically conductive (Like in metals ) & will not depend on moisture for conduction. Compound required for four earthing set is 10 bags 25 kg each.

- Make - Indelec/ Equivalent

Qty - 12 Bags 25Kg Each Approx.

c) GI Earthing Strip

Size - 25mm x 5mm

Qty - 40 Mts. For Six earthing system.

06 Nos.

#### IX. Installation of Earthing System with 25 x 5mm GI Strip

1. Firm shall carry out the digging work required for the earth pit of size 2 mtrs. Depth and 6" x 6" length and width, at specified location & it will be filled with carbon based earthing powder in proper proportion in mixture as per standard guidelines of Manufacturer & Install the earthing conductor.
2. Firm shall connect the earthing electrode with of GI Strip to the Feeder pillar.
3. Firm shall supply necessary bricks, cement, sand etc. required for earth PIT installation work.
4. The earth pit shall be properly covered with heavy duty PVC/metallic removable cover.

Qty: 06 no.s

### **SCHEDULE : 2**

#### **Job work of Supply, Installation, Testing & Commissioning of LED street light With Power Cables & Earthing System On Turnkey Basis lights from CNP-I fire station to CNP-I V main gate.**

##### I. Supply of 10Mtr height Street light pole with 100W LED light Pole & single arm bracket

.The pole shall be hot dip galvanized in single dipping method (70\*175) . The pole shall house a multi-way terminal block & MCB. Poles shall be continuously tapered circular conical cross section, presenting a good and pleasing appearance and based on proven design conforming to international standards, to give an assured performance, and reliable service. The pole shall be

suitable for wind loadings as per IS 875 part 3 1987 .An adequate door opening shall be provided at the base of the pole at a convenient location. Provision shall be given inside this door for fixing the electrical terminals. The opening shall be such that it permits clear access to the inside of the pole. The door opening shall be complete with a close fitting, vandal resistant, door; provided with a screw type locking facility

Std. Make Bajaj OCT/ equivalent along with necessary Foundation bolts Template,

\* Bracket single arm : Pole Bracket shall be provided with a single arm bracket as per the requirement of the project. Bracket shall be connected to the pole by using a proper

connection. Brackets also shall be hot dip galvanized .

100watt LED specifications : Luminaire System Efficacy (Lumen/watt) $\geq$  100 Lm/Watt ,Rated voltage 240 V AC 50 Hz,, AC Power Factor at full load  $\geq$  0.95

- Driver Efficiency (in %) Up to 100W:  $\geq$ 85
- Total Harmonics Distortion  $\leq$  10%
- LED chip Efficacy  $\geq$ 130 Lm/Watt
- Colour temperature 6500K
- Working life for LED Minimum 50,000 hours
- Colour Rendering Index(CRI)  $\geq$ 70

- LED Beam Angle  $\geq 120$
- Optic lens material (UV stabilized) Poly carbonate lens
- Input operating Voltage range and frequency 90 to 300 Volts AC at 50 Hz (  $\pm 2$  %)
- Automatic Higher voltage cut off
- Heat sink should be die-cast Aluminium along with sufficient heat sink fins to dissipate heat effectively.
- Operating temperature range  $-10^{\circ}\text{C}$  to  $80^{\circ}\text{C}$
- Short circuit Protection ,Over load protection ,Over Voltage protection & Reverse polarity protection
- The luminaire shall be protected against surges and transients ( Internal)  $\geq 8\text{Kv}$
- The luminaire shall be protected against surges and transients of  $\geq 10\text{KV}$  (External)
- The Luminaires casing/housing (single piece housing) shall be pressure die casted Aluminium alloy with higher thermal conductivity & The luminaire body must be corrosion resistant powder coated
- All fasteners must be of stainless steel
- Protection of the entire housing (both LED section and driver section) as per IS:10322 (Part 1):1982 latest IP66
- Extruded silicon loop gasket shall be provided in the lantern body to ensure a weather proof seal between the UV Glass cover and the metal housing to exclude the entry of the dust, water, insects etc.,
- Luminaires light transparency should be of Toughened glass
- Light Source SMD LED Chip as per LM 80/IS16106
- Driver components shall be industrial grade or above

Qty: 27 nos

## II. Supply & Installation of LED street light pole

The scope of work for Supply & Installation work is as below:-

- Provision of necessary foundation arrangements in finished masonry work for erection of LED Street light Pole
- Termination of incoming & outgoing cables into connection terminals of the LED street light pole through crimping of appropriate sizes of cable lugs & glands.
- All required accessories for installation of LED street light pole.
- Supply of Concreting material: 1 Cubic. Mtr per pole

Qty: 27 no.s

## III Supply of 10 sq. mm. $\times$ 4 core Aluminium Arm Cable

Voltage Grade : 1.1 KV

Identification Strips: Red, Yellow, Blue & Black

Confirming to : IS standards as applicable

Make: POLYCAB or equivalent

Qty: 600 mtrs.

IV Laying & Installation of 10 sq. mm. × 4 core Aluminium Armoured cable

- All required Cable Gland, Lugs, Clamp whichever is required for termination & installation work of the cable.
- Cable shall be undergrounded as per Standard specification.
- The Aluminium lugs will be used for connection to Aluminium bus bar.
- The accessories like lugs, cable glands, etc. will be of reputed make like Dowells, Jainson, etc.
- DWC pipe 50mm cover shall be used

Qty:600 mtrs

V. Supply of G.I Pipe for Road crossing Size- 100 mm, Material- GI

Qty:12 mtrs

VI. Laying & Installation of GI Pipe for Road crossing work of cable which includes digging of road by breaker & resurfacing the road with cement.

Qty: 12 mtrs.

VII. Supply and installation of Maintenance free earthing system With 8SWG G.I Wire.

Qty 27 nos

VIII. Shabadis tiles removal and re-fixing will be done as needed.

Qty:45 Brass approx..

IX. Supply of 2 core 1SQMM CU. Flexible cable polycab make or Equivalent.

Qty:300 mtrs

X Supply and Installation of Feeder Pillar STD-4 , 32A, IC with SDT &PT control

Qty:01 no.

**General Terms and conditions:- Applicable for both schedule I & II.**

1. The entire works being on turnkey basis, the firm may inspect the site with prior intimation to C NP to see the actual quantum of works which may include breaking of floor, construction of new cable trench, supply of chequered plates, any type of civil works in addition to the main scope of work. However, it is strongly recommended to inspect the site before submission of bid by the participating firm.

2. Any additional item/items i.e. Civil, Electrical, Mechanical or any category which are not mentioned in this tender but necessary for job successful installation and commissioning shall be the part of the order without any additional cost to Purchaser. Hence bidder firm must keep in mind these unforeseen works may be the part and necessity of project for successful installation and commissioning of the item/Items and quote accordingly.

3. The firm should attach the valid electrical contractor's license along with the quotation otherwise quotation will not be considered.
4. The entire work is on turnkey basis; hence all tools, tackles and all other related ancillary should be arranged by the firm.
5. The firm should take necessary precautionary measures and follow safety norms as per the safety codes.
6. During Execution of work, in case of any major or minor accident at site, it will be the sole responsibility of the firm and no compensation or penalty to any employee of the firm and their contractors will be borne by CNP.

### **C) MINIMUM ELIGIBILITY CRITERIA**

#### **SCHEDULE: 1**

**The following shall be the minimum eligibility criteria for selection of bidders:**

##### **1. Experience and past performance:**

The bidder (Manufacturer or principal of authorized representative-hereinafter referred simply as "The Bidder") should have Manufactured and Supplied, Installation, Testing & Commissioning of 03 nos of High Mast with LED Flood lights with associated item of similar or higher specification in any one year during last 5 years ending 31.03.2024.

##### **2. Capacity , Equipment & Manufacturing Facilities :**

The bidder should have annual capacity to manufacture Supply, Installation, Testing & Commissioning of 03 Nos of High Mast with LED Flood lights with associated item.

Note: All experience, past performance and capacity/ capability related data should be certified by the authorized signatory of the bidder firm.

##### **3. Financial Standing:**

(a) Average Annual turnover of the bidder firm should be more than Rs.12,41,300/- during last three years i.e. 2021-2022, 2022-2023 and 2023-2024.

(b) The net worth of the firm should not be negative in FY 2023-2024 and should not have eroded by more than 30% in the last three financial years i.e. 2021-2022, 2022-2023 and 2023-2024.

4. The bidder should give undertaking/declaration that they have read and understood all the terms (with technical specification) & conditions of tender documents and submitting unconditional acceptance to all terms & conditions.

5. The bidder shall submit offered product catalogue with technical bid.

4. The firm should attach valid authorization certificate obtained from manufacturer of LED Flood Light, Power Cable , Earthing System etc.
5. The interested bidder must be holding valid electrical contractor's licence issued by the competent authorities (State/Central) and copy of the same shall be enclosed along with the bid.

## **SCHEDULE: 2**

**The following shall be the minimum eligibility criteria for selection of bidders:**

### **1. Experience and past performance:**

a) For MSE/Start-up Firm : Capability -Equipment Manufacturing Facilities : The bidder firm should have capability to manufacture and Supply, Installation, Testing & Commissioning of LED Street Light with associated item.

b) For other firm : Experience and Past performance : The bidder firm may be Manufacturer/Proven Supplier/ Authorized dealer or distributor of Supply, Installation, Testing & Commissioning of LED Street Light with associated item or bidder may participated with manufacturing authorization form (issued by manufacturer of tender item)

2. The bidder should give undertaking/declaration that they have read and understood all the terms (with technical specification) & conditions of tender documents and submitting unconditional acceptance to all terms & conditions.

3. The bidder shall submit offered product catalogue with technical bid.

4. The firm should attach valid authorization certificate obtained from manufacturer of LED Street Light, Power Cable , Earthing System etc.

5. The interested bidder must be holding valid electrical contractor's licence issued by the competent authorities (State/Central) and copy of the same shall be enclosed along with the bid.

### **Note:-**

(i) In support of experience criteria, the bidder has to submit attested copies of P.O's, Experience certificates issued by customers.

(ii) All experience, past performance & capacity/ capability related/data should be certified by the authorized signatory of the bidder firm. The credentials regarding experience and past performance to the extent required as per eligibility criteria submitted by bidder may be verified from the parties for whom work has been done.

(iii) All financial standing data such as Balance Sheet, Profit & Loss account statement etc. should be certified by certified accountants e.g. Chartered Accounts. Financial statement duly certified by CA for year 2021-2022, 2022-2023 and 2023-2024 to be submitted with UDIN No.

**Bidder to furnish stipulated documents support of fulfillment of qualifying criteria. Non submission or incomplete submission of documents may lead to rejection of offer.**

## **D) SAFETY CODES TO BE FOLLOWED BY THE CONTACTORS/THEIR EMPLOYEES.**

1. The firm to whom the job work has been assigned will be primarily responsible to ensure the safety of all their employees working under them while they work inside factory premises.
2. The firm to whom the job work has been assigned will be responsible for any act of the contractors, which amounts to contravention of any provision of the Factory Act 1948 and the Maharashtra factory rules 1963.
3. The firm to whom the job work has been assigned will ensure and monitor the following:-
  - 3.1 The firm has to nominate one of the competent supervisors, who in addition to his duty will also be responsible to look after the safety of employees working under them and safety of nearby other plant equipment.
  - 3.2 The firm will provide personal protective equipment to his employees to ensure their safety.
  - 3.3 Electrical connection will be taken only with the written permission from the electrical department CNP.
  - 3.4 The firm will ensure that the hand tools, power tools, forklifts, Hydra, ladders, slings and equipment etc. are maintained in good working condition and will also ensure that they are safe and free from risk to employees.
  - 3.5 All the machines brought by contractor for their job work should be properly guarded/ maintained in proper condition for their safe working.
  - 3.6 All the lifting machines, lifting tackles, chain ropes, pulleys etc. will not be allowed in factory premises unless they are thoroughly and certified by the competent person(as per Factory act 1948) once in every Six month.
  - 3.7 In Case of any accident, the firm representative will arrange to inform it to the safety dept. CNP immediately. The agency will also arrange to inform the inspector of Factories Nashik. The agency will provide proper information to the inspector of factories and safety officer during their inspection.
  - 3.8 Selected contractor needs to provide PVR of Supervisor/ labour's/person's entering in press premises.

**E) Delivery Schedule:** The successful bidder has to successful Supply & Installation for the all project will be completed within 90 days from the date of issue of GeM Contract.

## **F) Payment Terms:**

(a) 100% Payment after completion of entire supply & installation after suitability and acceptance will be made within 30 days and on production of all required documents by the supplier such as Invoice in Triplicate, Guarantee Certificate, If any, etc. submitted to Store Dept., CNP.

**G) Liquidated damages clause:** If the Supplier fails to delivery any or all of the goods or fail to perform the services within the time frame(s) incorporated in the contract, CNP-Nashik shall, without prejudice to other rights and remedies available to CNP-Nashik under the contract, deduct from the contract, price, as liquidated damages, a sum equivalent to the 0.5% of the delivered price of the delayed goods and/or services for each week delay or part thereof until actual delivery or performance, subject to a maximum deduction of the 10% of the delayed goods' or services' contract price(s). If LD is levied the GST applicable on the LD shall also be collected from the firm.

**H) Please Click the link for further details and submit the acceptance of GIT and GCC as per the links:**



<https://www.spmcil.com/spmcil/UploadDocument/GIT.pdf>

<https://www.spmcil.com/spmcil/UploadDocument/GCC.pdf>

### **BIDDER'S CHECK LIST BEFORE TENDER SUBMISSION**

Sr. No.	Tender Submission Check Point	Check before submission on Tick (√)
1	Documentary Evidence (Earnest Money Deposit)	
2	Documentary Evidence - Experience & Past Performance	
3	Documentary Evidence - Capacity & Capability	
4	CA certified Financial Documents for FY 2021-2022, 2022-2023 and 2023-2024	
5	Declaration of Unconditional Acceptance	
6	Acceptance of GIT & GCC	
7	Offered Product Catalogue	
8	Manufacture Authorization Certificate (If applicable)	

#### **3. Forms of EMD and PBG**

Bidders can also submit the EMD with Account Payee Demand Draft in favour of

CURRENCY NOTE PRESS, A UNIT OF SPMCIL  
payable at  
NASHIK

Bidder has to upload scanned copy / proof of the DD along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.

#### **4. Forms of EMD and PBG**

Bidders can also submit the EMD with Banker's Cheque in favour of

CURRENCY NOTE PRESS, A UNIT OF SPMCIL  
payable at  
NASHIK

Bidder has to upload scanned copy / proof of the BC along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.

#### **5. Forms of EMD and PBG**

Bidders can also submit the EMD with Payment online through RTGS / internet banking in Beneficiary name

CURRENCY NOTE PRESS, A UNIT OF SPMCIL  
Account No.  
201003551111  
IFSC Code  
INDB0001451  
Bank Name

INDUSIND BANK  
Branch address  
ASHOKA MARG, NASHIK

. Bidder to indicate bid number and name of bidding entity in the transaction details field at the time of on-line transfer. Bidder has to upload scanned copy / proof of the Online Payment Transfer along with bid.

#### 6. **Forms of EMD and PBG**

Successful Bidder can submit the Performance Security in the form of Account Payee Demand Draft also (besides PBG which is allowed as per GeM GTC). DD should be made in favour of

CURRENCY NOTE PRESS, A UNIT OF SPMCIL  
payable at  
NASHIK

. After award of contract, Successful Bidder can upload scanned copy of the DD in place of PBG and has to ensure delivery of hard copy to the original DD to the Buyer within 15 days of award of contract.

#### 7. **Forms of EMD and PBG**

Successful Bidder can submit the Performance Security in the form of Fixed Deposit Receipt also (besides PBG which is allowed as per GeM GTC). FDR should be made out or pledged in the name of

CURRENCY NOTE PRESS, A UNIT OF SPMCIL, NASHIK  
A/C (Name of the Seller). The bank should certify on it that the deposit can be withdrawn only on the demand or with the sanction of the pledgee. For release of Security Deposit, the FDR will be released in favour of bidder by the Buyer after making endorsement on the back of the FDR duly signed and stamped along with covering letter. Successful Bidder has to upload scanned copy of the FDR document in place of PBG and has to ensure delivery of hard copy of Original FDR to the Buyer within 15 days of award of contract.

#### 8. **Forms of EMD and PBG**

Successful Bidder can submit the Performance Security in the form of Payment online through RTGS / internet banking also (besides PBG which is allowed as per GeM GTC). On-line payment shall be in Beneficiary name

CURRENCY NOTE PRESS, A UNIT OF SPMCIL  
Account No.  
201003551111  
IFSC Code  
INDB0001451  
Bank Name  
INDUSIND BANK  
Branch address  
ASHOKA MARG, NASHIK

. Successful Bidder to indicate Contract number and name of Seller entity in the transaction details field at the time of on-line transfer. Bidder has to upload scanned copy / proof of the Online Payment Transfer in place of PBG within 15 days of award of contract.

#### 9. **Generic**

Actual delivery (and Installation & Commissioning (if covered in scope of supply)) is to be done at following address

CURRENCY NOTE PRESS  
JAIL ROAD  
NASHIK ROAD  
NASHIK  
101

#### 10. **Certificates**

Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the

Bid document, ATC and Corrigendum if any.

11. **Warranty**

Warranty period of the supplied products shall be 1 years from the date of final acceptance of goods or after completion of installation, commissioning & testing of goods (if included in the scope of supply), at consignee location. OEM Warranty certificates must be submitted by Successful Bidder at the time of delivery of Goods. The seller should guarantee the rectification of goods in case of any break down during the guarantee period. Seller should have well established Installation, Commissioning, Training, Troubleshooting and Maintenance Service group in INDIA for attending the after sales service. Details of Service Centres near consignee destinations are to be uploaded along with the bid.

12. **Generic**

Data Sheet of the product(s) offered in the bid, are to be uploaded along with the bid documents. Buyers can match and verify the Data Sheet with the product specifications offered. In case of any unexplained mismatch of technical parameters, the bid is liable for rejection.

13. **Generic**

**Manufacturer Authorization:**Wherever Authorised Distributors/service providers are submitting the bid, Authorisation Form /Certificate with OEM/Original Service Provider details such as name, designation, address, e-mail Id and Phone No. required to be furnished along with the bid

14. **Generic**

1. The Seller shall not assign the Contract in whole or part without obtaining the prior written consent of buyer.
2. The Seller shall not sub-contract the Contract in whole or part to any entity without obtaining the prior written consent of buyer.
3. The Seller shall, notwithstanding the consent and assignment/sub-contract, remain jointly and severally liable and responsible to buyer together with the assignee/ sub-contractor, for and in respect of the due performance of the Contract and the Sellers obligations there under.

15. **Generic**

While generating invoice in GeM portal, the seller must upload scanned copy of GST invoice and the screenshot of GST portal confirming payment of GST.

16. **Generic**

Without prejudice to Buyer's right to price adjustment by way of discount or any other right or remedy available to Buyer, Buyer may terminate the Contract or any part thereof by a written notice to the Seller, if:

- i) The Seller fails to comply with any material term of the Contract.
- ii) The Seller informs Buyer of its inability to deliver the Material(s) or any part thereof within the stipulated Delivery Period or such inability otherwise becomes apparent.
- iii) The Seller fails to deliver the Material(s) or any part thereof within the stipulated Delivery Period and/or to replace/rectify any rejected or defective Material(s) promptly.
- iv) The Seller becomes bankrupt or goes into liquidation.
- v) The Seller makes a general assignment for the benefit of creditors.
- vi) A receiver is appointed for any substantial property owned by the Seller.
- vii) The Seller has misrepresented to Buyer, acting on which misrepresentation Buyer has placed the Purchase Order on the Seller.

## **Disclaimer/अस्वीकरण**

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and

conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

[This Bid is also governed by the General Terms and Conditions/ यह बिड सामान्य शर्तों के अंतर्गत भी शासित है](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws./जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।

**---Thank You/धन्यवाद---**