Government eProcurement System

Government eProcurement System

Published Corrigendum Details

Date : 03-Nov-2026 09:41 AM

Print

Organisation Chain :	SECURITY PRINTING AND MINTING CORPORATION OF INDIA-SPMCIL||CURRENCY NOTE PRESS NASHIK(MH)||Purchase Deptt -SPMCIL
Tender ID :	2026_SPMCI_288775_1
Tender Ref No :	6000019761
Tender Title :	TENDER DOCUMENTS FOR SUPPLY, INSTALLATION TESTING AND COMMISSIONING OF AIR HANDLING UNITS WITH ACESSORIES ON TURNKEY BASIS
Corrigendum Type :	Date

Corrigendum:2

Corrigendum Title	Corrigendum Description	Published Date	Document Name	Doc Size(in KB)
CORRIGENDUM-II	CORRIGENDUM-II (FOR EXTENSION OF DUE DATE AND AMENDMENT IN TECHNICAL BID DOCUMENTS)	03-Nov-2026 09:40 AM	AHUCII.pdf	480.07

Critical Dates

Publish Date	17-Sep-2026 12:05 PM	**Bid Opening Date**	18-Nov-2026 12:05 PM
Document Download/Sale Start Date	17-Sep-2026 12:05 PM	**Document Download/Sale End Date**	17-Nov-2026 12:05 PM
Clarification Start Date	NA	**Clarification End Date**	NA
Bid Submission Start Date	17-Sep-2026 12:05 PM	**Bid Submission End Date**	17-Nov-2026 12:05 PM
Pre Bid Meeting Date	01-Oct-2026 11:30 AM		

Corrigendum:1

Corrigendum Title	Corrigendum Description	Published Date	Document Name	Doc Size(in KB)
Corrigendum-I	EXTENSION OF DUE DATE	17-Oct-2026 07:18 PM	CORI.pdf	87.11

Critical Dates

Publish Date	17-Sep-2026 12:05 PM	**Bid Opening Date**	03-Nov-2026 12:05 PM
Document Download/Sale Start Date	17-Sep-2026 12:05 PM	**Document Download/Sale End Date**	02-Nov-2026 12:05 PM
Clarification Start Date	NA	**Clarification End Date**	NA
Bid Submission Start Date	17-Sep-2026 12:05 PM	**Bid Submission End Date**	02-Nov-2026 12:05 PM
Pre Bid Meeting Date	01-Oct-2026 11:30 AM		

Details Before Corrigendum

Critical Dates

Publish Date	17-Sep-2026 12:05 PM	**Bid Opening Date**	19-Oct-2026 12:05 PM
Document Download/Sale Start Date	17-Sep-2026 12:05 PM	**Document Download/Sale End Date**	17-Oct-2026 12:05 PM
Clarification Start Date	NA	**Clarification End Date**	NA
Bid Submission Start Date	17-Sep-2026 12:05 PM	**Bid Submission End Date**	17-Oct-2026 12:05 PM
Pre Bid Meeting Date	01-Oct-2026 11:30 AM		

चलार्थ पत्र मुद्रणालय, नासिक
CURRENCY NOTE PRESS, NASHIK
सिक्योरिटी प्रिंटिंग एंड मिंटिंग कॉरपोरेशन ऑफ इंडिया लिमिटेड
A Unit of Security Printing and Minting Corporation of India Limited
मिनीरत्न श्रेणी–1 सीपीएसई / Miniratna Category - I CPSE
भारत सरकार के पूर्ण स्वामित्वाधीन / Wholly owned by Government of India
जेल रोड, नासिकरोड,(महाराष्ट्र)– 422 101 / Jail Road, Nashik Road (Maharashtra) - 422 101
आई.एस.ओ. 9001:2015 एवं आई.एस.ओ.14001 :2015 प्रमाणित इकाई / ISO : 9001:2015 & ISO 14001:2015 Certified Unit

वेबसाईट / Website: https://cnpnashik.spmcil.com EPABX:00-91-253-2463730-39, 2405500 CIN : U22213DL2006GOI144763
ई–मेल / E-mail: cgm.cnp@spmcil.com Fax No.: 00-91-253-2464100 GST No. : 27AAJCS6111J3Z6

फ़ाइल क्र.सीएनपी/GEM/336-E-34/2026-27 दिनांक : 03.11.2026

शुद्धिपत्र-II / CORRIGENDUM-II

संदर्भ :निविदा क्रमांक .CPPP : 2026_SPMCI_288775_1 दिनांक: 17.09.2026
Ref: Tender No. CPPP : 2026_SPMCI_288775_1 Dated: 17.09.2026

www.etenders.gov.in पर प्रकाशित की गई उपरोक्त निविदा के संदर्भ में, इसमें शुद्धिपत्र-II के तहत निम्न संशोधन जारी किए जा रहे हैं ।
With reference to above tender which was published on the www.etenders.gov.in, further to this the following amendment is being issued under Corrigendum-II.

क्र/. SR. No.	विवरण Section/Page No./Clause No.) Reference : Webcast Tender Document(	वर्तमान प्रविष्टि के लिए (के स्थान पर) For Existing Entry (In Place of)	अब इस प्रकार पढें Now Read as
1.	Bid Submission End Date/Time	02.11.2026 at 12.05 PM	17.11.2026 at 12.05 PM
2.	Bid Opening Date/Time	03.11.2026 at 12.05 PM	18.11.2026 at 12.05 PM
3.	**Tender Documents : Section VI- List of Requirements : Clause no. 10 : Payments Terms -**	i. The 70% payment will be released for each line item for the Supply, Installation, testing and commissioning of Air Handling Units along with accessories such as chilled water piping, butterfly valves, balancing valves, Y-strainer etc., section wise used to run individual section as per actual measurement and operation of AHU with corresponding capacity in CFM. If the AHUs fail to operate during operation trial, there shall be no	i. The 80% payment shall be released (for each line item against the Supply, Installation, testing and commissioning of Air Handling Units along with accessories such as chilled water piping, butterfly valves, balancing valves, Y-strainer etc.) section wise used to run individual section as per actual measurement and operation of AHU with corresponding capacity in CFM. If the AHUs fail to operate during operation trial (for required CFM), there shall

		payment made to firm till operation of AHUs along with its accessories. ii. The balance 30% payment along with 100% payment towards standard commissioning of AHUs will be released for all sections after completion and acceptance of all the works related to the Supply, Installation, Testing and Commissioning of Air Handling Units with accessories after successful completion of FAT as per actual measurement of each line item and issuance of FAC.	be no payment made to firm till operation of AHUs (for required CFM) along with its accessories for each section. ii. The balance 20% payment along with 100% payment towards standard commissioning of AHUs will be released for all sections together after completion and acceptance of all the works related to the Supply, Installation, Testing and Commissioning of Air Handling Units with accessories after successful completion of FAT as per actual measurement of each line item and issuance of FAC.
4.	**Tender Documents : Section VII- General Terms and Conditions: Clause no. 05 :**	The firm will have to carry out the entire job on turnkey basis. The work will be carried out section wise and only one section at a time will be given. The details of sections are i. Section 1 - 50,000 CFM x 03 nos ii. Section 2 - 50,000 CFM x 04 nos iii. Section 3 - 50,000 CFM x 05 nos iv. Section 4 - 37,500 CFM x 05 nos v. Section 5 -	The firm Will have to carry out the entire job on turnkey basis. The work will be carried out section wise as mentioned below and only one section at a time will be given due to constraints of running AHUs required for production. i. Section 1 - 50,000 CFM x 03 nos ii. Section 2 - 50,000 CFM x 04 nos iii. Section 3 - 50,000 CFM x 05 nos iv. Section 4 - 37,500 CFM x 05 nos v. Section 5 - 50,000 CFM x 02 nos vi. Section 6 - 50,000

			50,000 CFM x 02 nos vi. Section 6 - 50,000 CFM x 03 nos vii. Section 7 - 37,500 CFM x 01 nos & 9,000 CFM x 01 nos	CFM x 03 nos vii. Section 7 - 37,500 CFM x 01 nos & 9,000 CFM x 01 nos The payments shall be done on an actual basis as per the BOQ submitted by the firm in the tender (within the limit of BOQ only). However, for BOQ serial numbers 15, 16,17,18,19, 20, 31, 32, 33, 34, 41, 42, 43, 44, 45, 46, 47, 48, 49, 50, 51, 52, 53, 92 & 94 payment shall be done on actual basis as per the BOQ submitted by the firm in the tender with the limit of maximum 10% of extra quantity used in completion of project. However, the firm will have to carry out the entire job on turnkey base i.e. Supply, Installation, Testing and Commissioning of Air Handling Units with accessories for BFS, BPS, SuSi-3, SuSi-4, SOI, SuNu-2 and Plate making complex in CNP Nashik on replacement basis. Any material or accessories which may or may not have been specifically mentioned in the BOQ but which is necessary for satisfactory and trouble free operation and maintenance of the AHUs and its accessories will be furnished by the firm without any extra cost.

5.	**Buyer Added Bid Specific ATC - GIT & GCC link**	**Please Click the link for further details of GIT and GCC as per the links :** GIT : https://www.spmcil.com/wp-content/uploads/2024/06/GIT-3.0-1.pdf GCC : https://www.spmcil.com/wp-content/uploads/2024/06/GCC-3.0-1.pdf

उपरोक्त निविदा की बाकी सभी नियमों एवं शर्तों में कोई परिवर्तन नहीं होगा ।
All other terms and conditions of above referred tender shall remain unaltered.

-sd/-
उप महाप्रबंधक (सामाग्री)/ Dy. General Manager (Materials)
कृते मुख्य महाप्रबंधक / For Chief General Manager

Tender No: 2026_SPMCI_288775_1- TENDER DOCUMENT FOR SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF AIR HANDLING UNITS WITH ACCESSORIES ON TURNKEY BASIS						
PRE BID MEETING HELD ON 01.10.2026 AT 11.30AM.						
Sr no	**Page no**	**Section no.**	**Clause no.**	**As per Tender**	**Query**	**CNP comments**
1	**13**	**VI**	**1**	Required Delivery Schedule : within twelve (12) Months from the date of issue of purchase order for the entire wok of Supply, installtion, testign and commissioning of air handling units with Accessories including PDI and FAT period	The delivery shall be within 12 months from the date of technical approval.	No Changes
2	**13**	**VI**	**5.1**	**Scope of Inspection:** The pre-dispatch inspection (PDI) shall be done by the CNP officials before the dispatch of material. i.e - Air hanlding units AHUs, Humidifers, Electrcial Panels, Distribution panels, chilled water pumps and condenser water pumps for sections wise as per matually agreed schedule for installtion at site (section wise)	PDI Shall be Applicable for the AHU, Electrical panels, Chilled water & Cooling water pump & hudifiers only. However the PDI Shall be visual only. Or specify if you required any run test at OEM factory. As the run test is possible for the AHU & Pumps only however the acurate data shall be not getting during the run test.	No Changes
3	14	**VI**	6	Final Acceptance Test (FAT) The FAT of AHUs along with accessories for all sections will be carried out for continoues 30 working days at a time ii The Firm will have to take minimum 06 readings of DBT & WBT at an interval of 01 hrs using sling pshchrometer in all sections and reports may be prepared for readings of temp and RH recorded in each section.	The final Acceptance Test (FAT) Shall be carried out for the continoues 07 working days at a time (section wise) The firm shall be put the data logger to take readings of Temp & RH at an interval of 01 Hrs. in all sections and generat the comuperised report for each section.	No Changes
4	14	**VI**	8	Warranty Clause : The firm will have to provide 24 months perfromance warranty for complete work including all the insatlled equipment with desired temp & RH in the various sections from the date of successful FAT.	As the work is carried out in phase manner and the FAT is also applicable in phase manner, hence we request that the warranty shall be considered 24 months from the successful FAT in Phase manner. (First come first basis)	No Changes

Tender No: 2026_SPMCI_288775_1- TENDER DOCUMENT FOR SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF AIR HANDLING UNITS WITH ACCESSORIES ON TURNKEY BASIS						
PRE BID MEETING HELD ON 01.10.2026 AT 11.30AM.						
5	15	**VI**	10	Payment terms : the 70% payment will be released for each lime item for the Supply, installtion, testing and commissioning of Air hanlding units along with accessories such as chilled water piping, butterfly valves, balancing valves, Y-stainer etc.. section wise used to run individual section as per actual measuremnt and operation of AHU with corresponding capacity in CFM, if the AHUs fail to operate during operation trail, there shall be no payment made to firm till operation of AHUs aling with Its accessories. ii. The balance 30% Payemnt along with 100% payment towards standard commissioning of AHUS will be released for all sections after completion and acceptance of all the works related to the Supply, installtion, testing and commissioning of Air handling units with accessories after sucessful compeltion of FAT as per actual measurement of each line item and issuarance of FAC.	Payment Terms : 80% Payment will be released with 100% GST for each line item against Supply. 10% payment shall be released against installtion of line items against varification of the measurement. 10% payment shall be released against commissioning and Final Acceptace test against each section.	Clarified that, after disscussion with technical dept./ Finance dept., if requried the amendment may be issued accoridingly.
6	15	**VI**	12	Other Requirment for bidders 12.2 Manufacturer's Authorisation Letter (AS per section XIV) : the Firm has to be submit manufacturer's Authorisation certificate for "Air Handling unit"	As the Section XIV is not available in tender documents, we consider the standard format of the OEM for the authorisation.	No Changes

Tender No: 2026_SPMCI_288775_1- TENDER DOCUMENT FOR SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF AIR HANDLING UNITS WITH ACCESSORIES ON TURNKEY BASIS						
PRE BID MEETING HELD ON 01.10.2026 AT 11.30AM.						
7	16	**VI**	14	**Liquidated Damages Clause :** Subject to GCC clause 28, if the supplier fails to deliver any or all of the goods or fails to perform the services within the time frame(s) incorporated in the contract, SPMCIL shall, without prejudice to other rights and remedies available to SPMCIL under the contract, deduct from the contract price, as liquidated damages, a sum equivalent to the ½% percent (or any other percentage if prescribed in the SCC) of the delivered price of the delayed goods and/ or services for each week of delay or part thereof until actual delivery or performance, subject to a maximum deduction of the 10% (or any other percentage if prescribed in the SCC) of the delayed goods' or services' contract price(s). During the above-mentioned delayed period of supply and / or performance, the conditions incorporated under GCC subclause 23.4 above shall also apply. In all such cases GST would not be applicable on LD.	The liquidated Damages : As this is work is depend on shutdown of each sections, as work is going on in existing faciltiy with min shutdown time. LD is 0.5% to max 5% against non delivered items only, However the dispatch confimration based on the shutdown shall be applicable or it shall be not applicbale against non dispatch confirmation.	No Changes
8	19	**VII**	1	Air handling unit technical specification.	1. Make mentioned is Citizen/ Zeco/ Edgetech or Equivalent, Any Erovent Certified make is acceptable - Please confirm 2. Kinldy confirm the thickness of ahu Panel. 3. Fan shall be EC or Plug type. 4. Cooling coil tube shall be min 12.5 mm dia. 5. Perfromance Data. Operating noise level in 50-70 DB range from 3 mtr distance - please confirm	With reference to Point no. 2. The firm's who have attend pre-bid meeting have sugessted that as per standard available in market thickness of AHU Panel can be kept 50mm. With reference Point No.03 : Fan shall be EC or Plug Type : Clarified that, after disscussion with technical dept., if requried the amendment may be issued accoridingly. Other Point no.1,4 & 5 : No Changes
9	26	**VII**	6	SITC of Electrical Panels for AHU- Section 1, 2,3,4,5,6	1. Electrical Panel shall be TTA or PTTA or CPRI Approved only- Please specify. 2. Manufacturer Authorisation certificate (Switchgea) shall be applicable for the Panel Manufacturer only. 3. As only ACB feeder shall be with modbus communication capacbility - Please confirm Accordinlgy you can get only power details on SCADA system	Point no. 3. : Clarified that, after disscussion with technical dept., if requried the amendment may be issued accoridingly. Other Point no.1 & 2 : No Changes

Tender No: 2026_SPMCI_288775_1- TENDER DOCUMENT FOR SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF AIR HANDLING UNITS WITH ACCESSORIES ON TURNKEY BASIS						
PRE BID MEETING HELD ON 01.10.2026 AT 11.30AM.						
10	28	**VII**	13	Design, SITC of Chilled water pumps along with Accessories	1. Specify the pump specification such as back pull out type horizontal split casing, MOC if impeller & Shaft, Mechnical seal etc... 2. Specify the Head & Flow rate of pump 3. Valves & stainers are part of pump or it shall be covered as indivual item in BOQ. 4. Electrical panel for the Pumps Shall be considered or use the existing panel with required modification.	No Changes
11	28	**VII**	14	Design, SITC of Condenser water pumps along with Accessories	1. Specify the pump specification such as back pull out type horizontal split casing, MOC if impeller & Shaft, Mechnical seal etc... 2. Specify the Head & Flow rate of pump 3. Valves & stainers are part of pump or it shall be covered as indivual item in BOQ. 4. Electrical panel for the Pumps Shall be considered or use the existing panel with required modification.	No Changes
12	34	**VII**	19	Supply and installtion of Thermal insualtion of Air handling unit	1. Specify the make of insualtion material 2. Specify the thickness of insualtion for supply air and return air	No Changes
13	34	**VII**	20	Supply and installtion of Acoustic insualtion of Air handling unit	1. Specify the make of insualtion material 2. Specify the thickness of insualtion	No Changes
14	48	**VII**	79	SITC of Temperature Gauge	Specify the Size of gauge	No Changes
15	48	**VII**	81	SITC of Auto Air vent	Specify the Size of Air vent	No Changes
16	49	**VII**	91	Supply and installtion of desk panel for AHU on/off and trip status in AC plant.	We understood this is audio annucation panel for all the AHU. Total - 42 + 24 = 66 nos. On/ Off & trip status considered. To operate and status we have to run a control cabel from AHU zone panel to plant room, hence it may chances to loss the signal against any breakdown or cabel failure. We propsoed the scada or BMS system for easy operation. (IP Base)	No Changes
17	51		5	The firm Will have to carry out the entire job on trunkey basis. The work will be carried out section wise and only one section at a time will be given The details of sections are.	Please, confirm the qty variation is applicable or not. If not than billing shall be as per the BOQ qty only.	All the firm's who have attend pre-bid meeting had requested for Qty. variation of material to be allowded for pipe, cable, cable tray, ducting, insulation, MS fabrication/structure. Clarified that, after disscussion with technical dept., if requried the amendment may be issued accoridingly.

Tender No: 2026_SPMCI_288775_1- TENDER DOCUMENT FOR SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF AIR HANDLING UNITS WITH ACCESSORIES ON TURNKEY BASIS						
PRE BID MEETING HELD ON 01.10.2026 AT 11.30AM.						
18	52	**General Terms & Conditions**	9	Necessary shutdown of centralised AC plant, if required shall be given to the firm on Sunday/ Holidays	Sunday/ Holidays Shutodwn is very limited, Apart from that We required at 15 - 20 days shutdown to carried out dismatalling and reinstalltion with required civil work for each section	No Changes
19	52		12	The firm will be allowed to work in the CNP premicsed during the regular working hours from 08 am to 05pm which may be further extended up to 07 pm	During the shutdown we required work min 18 Hrs. hence the working permission shall be arranged or approved.	No Changes
20	52		13.3	Site survey & data ceollection	CNP shall be provide the existing layout of buidling or section to prepare the detail design and drawing.	No Changes
21	54		13.6.7	The removing of false ceiling, air ducts, structural supports.walls etc. for the installtion of new chilled water pipe line will be carried out by the firm. After completion of chilled water pipiline, the removed false ceilling / air ducting etc.. Will be refixed by the firm.	only Existing False ceilling / air ducting shall be used.	No Changes
22	57		14	The firm shall provide technical service support as and when required for next 03 years after the warranty period without any financial obligation on CNP	During that period we have to provide only technical support externally shall be provided, No physical services such as PM, breakdown call or visit shall be applicable during this period	No Changes
23	59	IX		**Qualification/ Eligibility Criteria.** The bidder should have successfully supplied, installed and commissioned at least 12 nos of Air handling units (at least one number capacity minimum 50000 CFM) in single purchase order/ contact in last five year ending on 31.03.26	1. As a micro and small enterprises are exempted from experience and past perfromance criterial agaisnt submission of MSME certificate. 2 We request 50000 CFM capacity any ongoing work shall be consider. 2. Can allow the interim work completion was in March 2020 due to absent of final bill audit and concuded.	No Changes
24	13	IV		General Query : EMD Exemption regarding	MSME-registered organization and wish to avail the applicable EMD exemption against our valid MSME certificate	No Changes. Applicable as per tender documents